



Town of Sudbury

Board of Health

DPW Office Building
275 Old Lancaster Road
Sudbury, MA 01776
978 440-5479

2/21/17

Jonathan F.X. O'Brien, Chairman
Sudbury Zoning Board of Appeals
278 Old Sudbury Road
Sudbury, MA 01776

**Re: Coolidge Phase II
Aggregation of Flow**

Dear Mr. O'Brien:

In response to inquiries regarding sewage flow aggregation at Coolidge, it is my opinion that separate ownership has been demonstrated for Phase II using the criteria set forth in 310 CMR 15.011. Therefore, the project should not be subject to the Groundwater Discharge Permit Program. This opinion does not constitute an approval of the septic system. Full compliance with 310 CMR 15.00 (Title 5) must be demonstrated for the project prior to issuing an approval.

The Board of Health requested that the developer and their engineers explore innovative (I/A) treatment alternatives. Although not mandated by Title 5, I/A technologies could significantly improve wastewater quality and minimize the impact to groundwater.

Sincerely,

William Murphy
Director of Public Health